

Biodiesel

Date of sampling: 12.07.2017

Samples taken by: independent inspectors

TEST	UNIT	METHOD	RESULT
Acid value	mg KOH/g	EN 14104	0.10
Ash	% m/m	ISO 3987	< 0.01
Cetane number	-	EN ISO 5165	57.5
Cloud point	°C	IP 444	6
Cold filter plugging point	°C	BS EN 116	1
Copper corrosion	Class	EN ISO 2160	1a
Density at 15°C	kg/m ³	EN ISO 12185	881.3
Ester content	% m/m	EN 14103	96.8
Flash point	°C	ISO 2719	167
Iodine value	gl/100g	EN 14111	90
Viscosity at 40°C	mm ² /s	EN ISO 3104	4.65
Sodium & potassium content	mg/kg	EN 14108 & 14109	1.1
Calcium & magnesium content	mg/kg	EN 14538	0.1
Phosphorous	mg/kg	EN 14107	0.7
Methanol content	% m/m	EN 14110	0.01
Monoglyceride content	% m/m	EN 14105	0.34
Diglyceride content	% m/m	EN 14105	0.08
Triglyceride content	% m/m	EN 14105	0.01
Free glycerol	% m/m	EN 14106	0.005
Total glycerol	% m/m	EN 14105	0.08
Oxidation stability 110°C	hrs	EN 14112	> 8
Sulphur content	mg/kg	BS EN ISO 20846	9.9
Water content	mg/kg	EN ISO 12937	299