

Diesel / Gasoil

Date of sampling: 30.04.2019

Samples taken by: independent inspectors

TEST	UNIT	METHOD	RESULT
Ash	% m/m	ISO 6245	< 0.01
Carbon residue (10%)	% m/m	EN ISO 10370	< 0.01
Cetane index	-	EN ISO 4264	53.9
Cetane number	-	EN ISO 5165	52.3
Cloud point	°C	EN 23015	- 6
Cold filter plugging point	°C	EN 116	- 27
Colour (ASTM)	-	ISO 2049	-
Conductivity	pS/m	ISO 6297	127
Copper corrosion (3 hrs at 50°C)	rating	ISO 2160	1a
Density at 15°C	kg/m ³	EN ISO 12185	832.0
Dist: Recovered at 250°C	% v/v	EN ISO 3405	35.3
Dist: Recovered at 360°C	% v/v	EN ISO 3405	96.9
Flash point	°C	ISO 2719 A	65.0
Lubricity	µm	EN ISO 12156-1	384
Oxidation stability	g/m ³	EN ISO 12205	-
Sulphur content	mg/kg	EN 20846	7.0
Viscosity at 40°C	CST	EN ISO 3104	2.756
Water content	mg/kg	EN ISO 12937	44